

1 (1 11 4 1 1	Product
1. Shell material:	EN AW 2105
Al composition	EN AW-3105
Al condition	H16
Tensile strength R <sub>m</sub> , MPa	150-190
Elongation A50, %	≥3
Anisothropy, % max	≤2
Material thickness, mm	0,20±0,01
Note: Mechanical properties after a sin	mulated solving treatment
2. Lacquers and inks	
Internal lacquer type	Mod. vinyl
External lacquer type	Polyester/Mod. polyester
External inks type	Alkyd
3. Liner – pvc sealing compo	
Internal pressure	0,6 MPa
Max. mom. internal pressure	0,8 MPa
Filling goods: carbonated and nor	
juices, mineral water. Not suitable	
Pasteurization: approx. 20 min at	
Hot filling: approx. 95°C with coo	oling
Sterilization: approx. 20 min at 12	21°C
Sterilization: approx. 20 min at 12  4. Recommended application	21°C 1 details (Glass) – for PET
Sterilization: approx. 20 min at 12 4. Recommended application bottles adjust according to the	21°C 1 details (Glass) – for PET
Sterilization: approx. 20 min at 12 4. Recommended application bottles adjust according to the	21°C 1 details (Glass) – for PET
Sterilization: approx. 20 min at 12 4. Recommended application bottles adjust according to the specification:	21°C 1 details (Glass) – for PET
Sterilization: approx. 20 min at 12 4. Recommended application bottles adjust according to the specification: Head pressure force, N	n details (Glass) – for PET ne bottle manufacturing
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N	1900-2300 100-120 1 90-110
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a	1900-2300 100-120 1 90-110
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved	1900-2300 100-120 1 90-110
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:	1900-2300 100-120 1 90-110
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:  Depth of draw plunger, mm	a details (Glass) – for PET ne bottle manufacturing  1900-2300 100-120 1 90-110 nd can be varied according to the
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:  Depth of draw plunger, mm  Drawing diameter, mm	a details (Glass) – for PET ne bottle manufacturing  1900-2300 100-120 1 90-110 nd can be varied according to the  2,60 26,0
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification: Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm	a details (Glass) – for PET ne bottle manufacturing  1900-2300 100-120 1 90-110 nd can be varied according to the
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:  Depth of draw plunger, mm  Drawing diameter, mm  Pre-centering diameter, mm	1900-2300   100-120     90-110     12,60     26,0     28,4+0.1
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:  Depth of draw plunger, mm  Drawing diameter, mm  Pre-centering diameter, mm  6. Relevant bottle neck finish	1900-2300   100-120   90-110   nd can be varied according to the   2,60   26,0   28,4+0,1   nd cases:
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification: Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish:	1900-2300   100-120   90-110   nd can be varied according to the   2,60   26,0   28,4+0,1   nd cases:
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish:  MCA 1 CE.T.I.E. GME 32.00	1900-2300   100-120   90-110   100
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification: Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish: MCA 1 CE.T.I.E. GME 32.00 MCA 2 CE.T.I.E. GME 32.00	1900-2300   100-120   10
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification: Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish: MCA 1 CE.T.I.E. GME 32.00 MCA 2 CE.T.I.E. GME 32.00 MCA 3 CE.T.I.E. GME 32.00	1900-2300   100-120   90-110   100
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N  Thread roller pressure force, N  Undertuck roller pressure force, N  Note: These values are starting ones a results to be achieved  5. Capping try dimension:  Depth of draw plunger, mm  Drawing diameter, mm  Pre-centering diameter, mm  6. Relevant bottle neck finish  Type of bottle finish:  MCA 1 CE.T.I.E. GME 32.00	1900-2300   100-120   10
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification:  Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish:  MCA 1 CE.T.I.E. GME 32.00 MCA 2 CE.T.I.E. GME 32.00 MCA 3 CE.T.I.E. GME 32.00 MCA 7,5R CE.T.I.E. GME 32.00	1900-2300   100-120   10
Sterilization: approx. 20 min at 12  4. Recommended application bottles adjust according to the specification: Head pressure force, N Thread roller pressure force, N Undertuck roller pressure force, N Note: These values are starting ones a results to be achieved  5. Capping try dimension: Depth of draw plunger, mm Drawing diameter, mm Pre-centering diameter, mm  6. Relevant bottle neck finish Type of bottle finish: MCA 1 CE.T.I.E. GME 32.00 MCA 2 CE.T.I.E. GME 32.00 MCA 3 CE.T.I.E. GME 32.00 MCA 7,5R CE.T.I.E. GME 32.00 MCA 7,5R CE.T.I.E. GME 32.00 MCA 7,5R CE.T.I.E. GME 32.00	1900-2300   100-120   10

Pilfer-proof HSC 28×15,4	
8. Closure drawing: Drawing ID -	- 28×15,4_106
Ø28,7±0.4  Ø27.7±0.2  Ø27.6min i/dia of perforation  Ø28.3±0.4 i/dia of skirt end  Ø29,2±0.4	4.5±0.4

Number of flutes/knurls	45±2
Weight, g	1,35±0,04

## 9. Packaging specification:

Quantity, pcs	5800	
Box dimensions – external, mm	600×400×360	
Cardboard type	Corrugated five layer cardboard	
Polyethylene sack	MDPE – non-toxic, anti-static, <100 ppm Pb, Cd, Hg, Cr <sup>+6</sup>	
Adhesive strip (Scotch)	48 mm	
Product identification	Labeling	
Pallet type – Euro pallet	Dimension: 1200×800×*	
* the overall pallet height may vary according to the customer's requirements		
Outside packing	Stretch wrapped	
Pallet identification	Labeling	

## 10. Storage and usage

quality, etc.

rotation (slip torque), Nm

reached one week after application.

The torque needed to break the tamper evident band (break torque), Nm

7. Opening torques (dry neck finish):

Note: It is possible immediately after application the slip torque to be higher than the values indicated in this specification sheet. The specified values are

Note: The break torques depend from the particular application, from the torques applied by the capping heads, the type and the bottle neck finish

The torque needed to start the closure

The closures shall be stored in well-ventilated area, away from direct sunlight, strong vapors and odors at temperatures (5-30)°C for the period of 2 (two) years after a date of production. The closures should be used following the principle "first to come – first to go" (FIFO). Pallets should not be double stacked.

0,70-1,80







